

ER. K.VENKATESAN, M.E., B.Tech., M.B.A
MSC(REV), A.I.V., M.I.E., Dip.Astro.,
CONSULTING CIVIL ENGINEER,
L.I.C PANEL VALUER &
LICENCED BUILDING SURVEYOR
VELLORE CITY MUNICIPAL CORPORATION
VELLORE DISTRICT.

NO.1, GDS COMPLEX, FIRST FLOOR,
GREEN CIRCLE VELLORE
VELLORE - 632004.
Cell No. 9345305948, 8300869321

DATE : 20.05.2025.


STRUCTURAL SOUNDNESS CERTIFICATE FOR EDUCATIONAL BUILDING.
STATEMENT ACCOMPANYING FORM-A

- | | |
|--|---|
| 1. Name of the building and
Door no. of the building | : BRILLS VIDYASHRAM SCHOOL
in S.F.No.81
Kathiyavadi Village & Panchayat,
Walaja Taluk, Ranipet District - 632 509. |
| 2. Location (Street no. ward no. No.
Name of place
Corporation/Union/ Municipality/Panchayat | : In S.F.No.81
Kathiyavadi Village & Panchayat,
Walaja Taluk, Ranipet District - 632 509. |
| 3. Year of construction | : 2019 Ground Floor : 8,266 Sqft. |
| 4. Approximate Cost of Construction as per
Current Rate | : 150 Lakhs. |
| 5. Purpose for which the building is | : Educational purpose. |
| 6. Details of construction of the building | : (Particulars of the foundation, soil,
Specification of various parts under). |
| (i) Soil type | : Hard Gravel |
| (ii) Foundation | : RCC column |
| (iii) Basement | : RCC column |
| (iv) Super structure | : Brick work in Cement Mortour |
| (v) Floor & Roof, are to be given | : Flooring: Granite Flooring.
Roofing : R.C.C Roof. |
| 7. Period for which the licence is required | : May be issued FROM: <u>01.06.2025 TO 31.05.2028</u>
(inclusive of both days) for <u>THREE YEARS</u> only. |
| 8. Number of persons to be
Accommodated | : 270 (Two Hundred and Seventy Students only). |


ER. K. VENKATESAN
B.Tech., ME(Struct.), MBA., M.Sc.(REV), D.Astro., M.I.E., A.I.V
Panel Engineer
With The Collector of Ranipettal District
No. 1, GDS Complex, First Floor, New Bye-Pass Road,
SIGNATURE OF THE ENGINEER.
Ph : 83008 69321 / 93453 05948

Certified that no additional or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of the building or a portion of the building originally is changed or altered subsequently. No inflammable material (shaminas /thatched) will be used either in the future or at present. If any such building are erected after issue of this certificate, the undersigned owner of the building will be held responsible for any mishap, that may occur later & this certificate automatically get cancelled.


Mrs. DEEPA THUKKARAMAN
D.A., M.Phil., B.Ed.,
Principal
Brills Vidyashram School,
Kathiyavadi, Arcot, Ranipet Dist., - 632 509.


SIGNATURE OF THE OWNER
OF THE BUILDING

For BRILL'S VIDYASHARAM


CORRESPONDENT


Annexure - "II" To "Statement Accompanying Form -A"

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of the educational building originally is changed or altered subsequently.

This is future to certify that no thatched buildings / inflammable roof building are used for conducting any classes with in the Educational premises. Anythatched building constructed / used after issue of this certificate, I would be held responsible for fire accident / mishap that may occur later and that I am aware that it is a punishable crime.

This is also understood that if there are any adjacent / first floor or other buildings of any type within the premises of this Educational building which are not opted for this Educational purpose and their conditions may also be brought under the risk of my own.

DATE : 20.05.2025.



SIGNATURE OF OWNER



Mrs. DEEPA THUKKARAMAN
M.A., M.Phil., B.Ed.,
Principal
Brills Vidyashram School,
Kathiyavadi, Arcot, Ranipet Dist., - 632 509.

For BRILL'S VIDYASHARAM

CORRESPONDENT

ER. K. VENKATESAN, M.E., B.Tech., M.B.A.
MSC(REV), A.I.V., M.I.E., Dip. Astro.,
CONSULTING CIVIL ENGINEER,
L.I.C PANEL VALUER &
LICENCED BUILDING SURVEYOR
VELLORE CITY MUNICIPAL CORPORATION
VELLORE DISTRICT.

NO.1, GDS COMPLEX, FIRST FLOOR,
GREEN CIRCLE VELLORE
VELLORE - 632004.
Cell No. 9345305948, 8300869321

DATE: 20.05.2025

STRUCTURAL SOUNDNESS CERTIFICATE RELATING TO EDUCATIONAL BUILDING
FORM- B

Form of certificate of structural soundness under sub-section (4) of section 4 of the Tamil Nadu Public Buildings (licensing) Act, 1965 (Tamil Nadu Act 13 of 1965) referred to in Rule 4 of the Tamil Nadu Public Building (licensing) Rules, 1966.

I certified that I have inspected the building mentioned in the statement below and I have satisfied myself that the building is structurally sound to be used as a public building for the purpose noted in the statement. The structural soundness of the building is verified taking into account the loading as per the latest Bureau of Indian Standard 895.A license may be granted for the period. FROM: 01.06.2025 TO 31.05.2028 for **THREE YEARS** only (inclusive of both days).

Er. K. VENKATESAN
B.Tech., ME(Struct.), MBA., M.Sc.(REV), D.Astro., MIE., ANV.
Panel Engineer
With The Collector of Ranipettai District
No. 1, GDS Complex, First Floor, New Bye-Pass Road,
Green Circle, Vellore - 632 004, Tamil Nadu.
Ph : 83008 69321 / 93453 05948
SIGNATURE OF THE ENGINEER.

DATE: 20.05.2025

STATEMENT TO ACCOMPANY THE CERTIFIED OF STRUCTURAL SOUNDNESS

1. Location of the Building : **BRILLS VIDYASHRAM SCHOOL**
Punjai S.F.No.81
Kathiyavadi Village & Panchayat,
Walaja Taluk, Ranipet District - 632 509.
2. Age of construction : 6 Years Old.
3. Purpose for which the building is Certified for use : Educational Purpose
4. The Period for which the building : **May be issued from : 01.06.2025 TO 31.05.2028**
5. License will be structurally sound : (inclusive of both days) for **THREE YEARS** only.
6. Number of persons to be accommodated : 270 (Two Hundred and Seventy Students only).

7. Remarks:

1. This certificate covers the "ABOVE MENTIONED BUILDING" only and does not Include any other structure or buildings within the premises used for other purpose.
2. Periodical repairs and renovations shall be carried out to the above mentioned buildings.
3. No. inflammable structures must be allowed within the above premises, Including thatched/shaminas.
4. If this certificate is tampered with illegally/unauthorized without the knowledge, permission and signature of the undersigned this certificate automatically cancelled.

Mrs. DEEPA THUKKARAMAN
M.A., M.Phil., B.Ed.,
Principal
Brills Vidyashram School,
Kathiyavadi, Arcot, Ranipet Dist., - 632 509.

For BRILL'S VIDYASHRAM SCHOOL
Er. K. VENKATESAN
B.Tech., ME(Struct.), MBA., M.Sc.(REV), D.Astro., MIE., ANV.
Panel Engineer
With The Collector of Ranipettai District
No. 1, GDS Complex, First Floor, New Bye-Pass Road,
Green Circle, Vellore - 632 004, Tamil Nadu.
Ph : 83008 69321 / 93453 05948
CORRESPONDENT

ER. K.VENKATESAN, M.E., B.Tech., M.B.A.
 MSC(REV), A.I.V., M.I.E., Dip.Astro.,
 CONSULTING CIVIL ENGINEER,
 L.I.C PANEL VALUER &
 LICENCED BUILDING SURVEYOR
 VELLORE CITY MUNICIPAL CORPORATION
 VELLORE DISTRICT.

NO.1, GDS COMPLEX, FIRST FLOOR,
 GREEN CIRCLE VELLORE
 VELLORE - 632004.
 Cell No. 9345305948, 8300869321

DATE: 20.05.2025

STRUCTURAL SOUNDNESS CERTIFICATE RELATING TO EDUCATIONAL BUILDING
 Form - C

(Form of certificate of structural soundness under sub section of the Tamil Nadu Public Building (Licensing) act of 1965 referred in rule of the Tamilnadu Buliding Licensing Rule 1966)


I hereby certify that i have inspection the building mentioned in the statement and furnish below its salient technical features.

S.No	(1).Foundations	:	RCC Framed Structure & Isolated Footing
1.	Depth below ground level	:	2.44m
2.	Nature of soil met with at foundation level	:	Hard Gravel
3.	Pressure of foundation	:	100 KN/sq.m.
4.	Probable safe bearing capacity of the soil at foundation	:	200 KN/sq.m.
S.No	(2). Super Structure	:	
1.	Maximum stress in the mat critical section of masonry and concrete	:	Masonry - 0.20 N/mm ² Concrete - 5.0 N/mm ²
2.	Nature of masonry and concrete and its safe permissible	:	Brick Work - 0.35 N/mm ² Concrete - 9.00 N/mm ²

The structural soundness of the building has been verified by me with reference to ISI loading standards 875(latest) version and other relevant Indian standard and code of practice and declare that the building is structurally sound to be used as a public building for the purpose noted in the statement.

License may be granted for the period FROM: 01.06.2025 TO 31.05.2028 for Three Years only.

PLACE: Vellore
 DATE : 20.05.2025.


SIGNATURE OF ENGINEER
E.R. VENKATESAN
 B.Tech., ME(Struct), MBA, M.Sc.(REV), D.Astro, MIE, AN.
 Panel Engineer
 With The Collector of Ranipettal District
 No. 1, GDS Complex, First Floor, New Bye-Pass Road,
 Green Circle, Vellore - 632 004, Tamil Nadu.
 Ph : 83008 69321 / 93453 05948


Mrs. DEEPA THUKKARAMAN
 M.A., M.Phil., B.Ed.,
 Principal
 Brills Vidyashram School,
 Kathiyavadi, Arcot, Ranipet Dist., - 632 509.

For BRILL'S VIDYASHARAM

CORRESPONDENT

ER. K.VENKATESAN, M.E., B.Tech., M.B.A.
MSC(REV), A.I.V., M.I.E., Dip. Astro.,
CONSULTING CIVIL ENGINEER,
L.I.C PANEL VALUER &
LICENCED BUILDING SURVEYOR
VELLORE CITY MUNICIPAL CORPORATION
VELLORE DISTRICT.

NO.1, GDS COMPLEX, FIRST FLOOR,
GREEN CIRCLE VELLORE
VELLORE - 632004.
Cell No. 9345305948, 8300869321


DATE: 20.05.2025

STRUCTURAL SOUNDNESS CERTIFICATE RELATING TO EDUCATIONAL BUILDING.

DECLARATION

1. Er. K. VENKATESAN, M.E., B.Tech., M.B.A, Msc, (REV) A.I.V., M.I.E., son of Thiru C.KUPUSAMY residing at NO.95 L.I.C Colony Kagithapattarai ,Vellore Municipal corporation. Do here by declare that I possess the qualification and experience specified in the Table Rule II of Tamil Nadu Public Buildings (Licensing Rule 1996) for issuing the certificate of structural soundness of the building covered by the certificate.

I am an APPROVED & REGISTERED ENGINEER with L.I.C OF INDIA VELLORE DIVISION under "Tamil Nadu Public Buildings (Licensing) act & rule, 1966" to issue the structural stability certificates to Public buildings under reference.


Er. K. VENKATESAN
B.Tech., ME(Struct.), MGA., M.Sc.(REV), D.Astro., MIE., AIV.
Panel Engineer
With The Collector of Ranipettai District
No. 1, GDS Complex, First Floor, New Bye-Pass Road,
Green Circle, Vellore - 632 004, Tamil Nadu.
Ph : 83008 69321 / 93453 05948

SIGNATURE OF THE ENGINEER

- | | |
|------------------------------|--|
| 1. Name in block letters | : Er.K. VENKATESAN |
| 2. Engineering qualification | : M.E., B.Tech., M.B.A Msc.(REV) A.I.V.M.I.E., |
| 3. No. Of year's experience | : 33 years as a Civil Engineer, |

Approved Engineer by the Board of Engineers
Tamil Nadu Govt. PWD, Minutes.
Lt. No. AEE/T10/BOE004-26/2023, dt: 05.09.2023

Panel Engineer with the collector of
Vellore district.
R.Dis.No.H2/6822/2022 Dated 14.03.2024


Mrs. DEEPA THUKKARAMAN

M.A., M.Phil., B.Ed.,
Principal
Brills Vidyashram School,
Kathiyavadi, Arcot, Ranipet Dist., - 632 509.

PLACE: Vellore
DATE : 20.05.2025.

For BRILL'S VIDYASHARAM


CORRESPONDENT



Er. K. VENKATESAN
B.Tech., ME(Struct.), MGA., M.Sc.(REV), D.Astro., MIE., AIV.
Panel Engineer
With The Collector of Ranipettai District
No. 1, GDS Complex, First Floor, New Bye-Pass Road,
Green Circle, Vellore - 632 004, Tamil Nadu.
Ph : 83008 69321 / 93453 05948

Er. K.VENKATESAN,
M.E., M.B.A., M.SC.(REV)., Dip.Astro., M.I.E., A.I.V.
Panel Engineer with
The Collector of Ranipet District.

FORM E

[Form of report to be made to the competent authority by inspecting authorities or officers appointed under other Acts under section 28 of the Tamil Nadu Public Buildings (Licensing) Act, 1965 (Tamil Nadu Act XIII of 1965) referred to in rule 7 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966.]

- | | |
|---|--|
| 1. Name and designation of inspecting authority or officer appointed or having jurisdiction under any other Act or law. | : Er. K.VENKATESAN,
M.E., M.B.A. MSC (REV), Dip.Astro., M.I.E., A.I.V.,
Panel Engineer with
The Collector of Ranipet District. |
| 2. Location of the building inspected
(Door number, Street number,
Name of place i.e.,
Municipal Corporation/ Municipality/
Panchayat or Panchayat
Union/Township/Cantonment). | : BRILLS VIDYASHRAM SCHOOL
Punjai S.F.No.81
Kathiyavadi Village & Panchayat,
Walaja Taluk, Ranipet District - 632 509. |
| 3. Date of inspection | : 20.05.2025 |
| 4. Purpose for which the building is used | : Educational Purpose. |
| 5. Nature of defects noticed | : Nil . |
| 6. Suggestions for rectifying defects | : Nil . |
| 7. If in a dangerous condition,
immediate steps recommended to be taken. | : Nil . |


Er. K. VENKATESAN
B.Tech., ME(Struct.), MBA., M.Sc.(REV), D.Astro., M.I.E., A.I.V.
Panel Engineer
With The Collector of Ranipettai District
No. 1, GDS Complex, First Floor, New Bye-Pass Road,
Green Circle, Vellore - 632 004, Tamil Nadu.
Ph : 83008 69321 / 93453 05948


Signature of inspecting authority
or officer appointed or having
jurisdiction.

To
The Personal Assistant to the Collector of Ranipet /
Revenue Divisional Officer/Tahsildar.


Mrs. DEEPA THUKKARAMAN

M.A., M.Phil., B.Ed.,
Principal

Brills Vidyashram School,
Kathiyavadi, Arcot, Ranipet Dist., - 632 509.

For BRILL'S VIDYASHARAM

CORRESPONDENT

Proceedings of the District Collector, Ranipet

Present: Tmt.S.Valarmathi, I.A.S.,

R Dis No H2/6822/2022

Dated:14.03.2024

Sub Tamil Nadu Public Building (Licensing) Act 1965 Inclusion of the name of Er. K. Venkatesan in the panel of Private Practicing Engineers under Class-IA in Ranipet District - Orders issued.

- Ref: 1. Thiru. K. Venkatesan, No1, GDS Complex, 1st floor, New Bye - Pass Road, Green Circle, Vellore - 04, application dt. 27.10.2021.
2. This Office Lr.No.Rc.No.H2/6822/2022, dt.23.02.2023
3. Engineer-in Chief. (Buildings) & Chief Engineer (Buildings) Chennai Region, PWD, Chennai.
Lr. No.AEE/T10/BOE004-26/2023, dt: 05.09.2023.

Order:

In reference 1st cited, Thiru. K. Venkatesan, No1, GDS Complex, 1st floor, New Bye - Pass Road, Green Circle, Vellore had submitted requisition to include his name in the panel of Private practicing Engineers under Class IA (One A) list of Ranipet District.


2) In reference 2nd cited read above, a proposal was sent to the Engineer-in-Chief, Public Works Department (General), Chennai regarding recommending inclusion of the Individual's name in the list of panel of Private Engineers under Class IA (One A) category.

3) In reference 3rd cited the Engineer-in-Chief (Buildings) & Chief Engineer (Buildings) Chennai region, PWD, Chepauk, Chennai has stated that the approved the inclusion of the name of Thiru. K. Venkatesan, No1, GDS Complex, 1st floor, New Bye - Pass Road, Green Circle, Vellore to be included in the panel of Private Practicing Engineers under Class IA (One A) category (Buildings, the cost of which exceeds Rs.50.00 lakhs as per G.O.Ms.No.43, Municipal Administration & Water Supply (MA4) Department, dated 17.2.2011) in Ranipet District.

4) As per the recommendations of the Engineer-in Chief, WRD and Chief Engineer (General) PWD, Chepauk, Chennai in his letter third read above, the name of Thiru. K. Venkatesan is ordered to be included in the panel of Private Practicing Engineers under Class IA category (Buildings, the cost of which exceeds Rs.50.00 lakhs as per G.O.Ms.No.43, Municipal Administration & Water Supply (MA4) Department, dated 17.2.2011) in Ranipet District.

5) All Revenue Divisional Officers and Tahsildars of Ranipet District are instructed to accept the public building soundness certificate issued by Thiru. K. Venkatesan subject to conditions.


Mrs. DEEPA THUKKARAMAN
M.A., M.Phil., B.Ed.,
Principal
Brills Vidyashram School,
Kathiyavadi, Arcot, Ranipet Dist., - 632 509.

Sd/-S Valarmathi,
District Collector,
Ranipet.
For BRILL'S VIDYASHARAM

//By Order//
CORRESPONDENT
Personal Assistant
to Collector (General)

To:

Thiru. K. Venkatesan.

No1, GDS Complex,

1st floor, New Bye - Pass Road,

Green Circle, Vellore - 04.

Copy to: Revenue Divisional Officer,
Ranipet/Arakonam.

Copy to:

The Engineer-in Chief, WRD and Chief Engineer (General) PWD, Chempauk, Chennai.


Mrs. DEEPA THUKKARAMAN
M.A., M.Phil., B.Ed.,
Principal
Brills Vidyashram School,
Kathiyavadi, Arcot, Ranipet Dist., - 632 509.

For BRILL'S VIDYASHRAM


CORRESPONDENT